DIN-RAIL MOUNTING KITS				
MODEL	PART NUMBER FOR KIT*			
	LONG	SHORT	PERPENDICULAR	
SINGLE OUTPUT A	-С ТО Д-С			
FAW 15W FAW 25W FAW 50W FAW 100W FAW 150W	DIN FAW-15L DIN FAW-25L DIN FAW-50L DIN FAW-100L DIN FAW-150L	DIN FAW-15S DIN FAW-25S DIN FAW-50S DIN FAW-100S DIN FAW-150S	DIN FAW-15P DIN FAW-25P DIN FAW-50P DIN FAW-100P DIN FAW-150P	
HSM 1000W HSM 1500W	DIN HSM-L DIN HSM-L	NA NA	NA NA	
RAX 50W RAX 100W RAX 175W RAX 300W	DIN RAX-50L DIN RAX-100L DIN RAX-175L DIN RAX-300L	DIN RAX-50S DIN RAX-100S DIN RAX-175S DIN RAX-300S	DIN RAX-50P DIN RAX-100P DIN RAX-175P DIN RAX-300P	
RCW 350W RCW 750W	DIN RCW-350L DIN RCW-750L	DIN RCW-350S NA	DIN RCW-350P DIN RCW-750P	
RKW 30W RKW 50W RKW 100W RKW 150W RKW 300W RKW 600W RKW 1500W	DIN RKW-30L DIN RKW-50L DIN RKW-100L DIN RKW-150L DIN RKW-300L DIN RKW-600L DIN RKW-1500L	DIN RKW-30S DIN RKW-50S DIN RKW-100S DIN RKW-150S DIN RKW-300S NA NA	DIN RKW-30P DIN RKW-50P DIN RKW-100P DIN RKW-150P DIN RKW-300P DIN RKW-600P NA	
MULTI OUTPUT A-C TO D-C				
KRW 40W MRW 35W MRW 50W MRW 65W	DIN KRW-L DIN MRW-150L DIN MRW-160L DIN MRW-170L	DIN KRW-S DIN MRW-150S DIN MRW-160S DIN MRW-170S	DIN KRW-P DIN MRW-150P DIN MRW-160P DIN MRW-170P	
PROGRAMMABLE A-C TO D-C				
PAT 20W	DIN PAT-L	DIN PAT-S	NA	
PTR 50W	DIN PTR-L	NA	NA	
SINGLE OUTPUT D-C TO D-C				
ERD 30W ERD 60W ERD 150W	DIN ERD-30L DIN ERD-60L DIN ERD-150L	DIN ERD-30S DIN ERD-60S DIN ERD-150S	DIN ERD-30P DIN ERD-60P DIN ERD-150P	

\* For factory-installed DIN-Rail mounting clips, add the suffix "-DL" or "-DS" or "-DP" to the model number for, respectively, clips to mount in the long (L), short (S) or perpendicular (P) directions. NOTE: For UL 508 recognition, the factory-installed clips and label are required.




FAW mounted to DIN-Rail in the long orientation

Selected Kepco power supplies can be mounted on a DIN-Rail. Kits are available for mounting the modules in a long, short or perpendicular fashion, as illustrated. The kits are comprised of DIN-Rail clips mounted to adapter plates that can be fastened to the power supply's mounting holes. Each kit contains two clips, brackets and hardware. The kits for open or pc card power supplies include the enclosure. Cable kits are included for those models that use input/output connectors. The clips can be ordered factorymounted to the selected power supply by adding a suffix to the power supply's model number. To mount in the long direction, the suffix is -DL. To mount in the short direction, the suffix is -DS. To mount perpendicularly to the DIN-Rail, the suffix is -DP.

DIN-Rail mounting allows power modules to be mounted in locations and in orientations that would not be possible otherwise. This can free up valuable space for equipment which require panel exposure for control and display. DIN-Rails are widely used in Europe and are increasing in popularity for industrial controls in the United States.


The modules are easily fastened and removed from the rail without tools. All DIN-Rail mounted FAW and the RCW 350 Watt models have been tested and approved to UL 508 and are listed constant as Miscellaneous Apparatus: Open Frame.

To mount some models in the (S) short direction, clearance requirements must be observed as shown in the drawing and chart on the next page.




KEPCO, INC. • 131-38 Sanford Avenue • Flushing, NY 11352 USA • Tel: (718) 461-7000 • Fax: (718) 767-1102 Email: hq@kepcopower.com • www.kepcopower.com/din.htm


## **DIN-Rail Long Orientation**



## **DIN-Rail Short Orientation**



## **DIN-Rail Perpendicular Orientation**




NOTE: Select this mounting option only in installations that will not be subject to shock loading.



## **DIN-RAIL CLEARANCE REQUIREMENTS**

MODEL	L Length in Inches See Clearance Drawing	B (L/2)-3	D Clearance in Inches See Clearance Drawing
DIN-ERD 60W-DS	7.3	0.65	0.22
DIN-ERD 150W-DS	9.7	1.85	0.63
DIN-FAW 50W-DS	6.5	0.25	0.09
DIN-FAW 100W-DS	7.9	0.95	0.32
DIN-FAW 150W-DS	7.9	0.95	0.32
DIN-RAX 50W-DS	7.5	0.75	0.26
DIN-RAX 100W-DS	7.9	0.95	0.35

This table lists the minimum clearance required to install specific Kepco power supplies on the DIN-Rail when the (S) short option is chosen. The following formula was used:  $D = B X \sin 20^{\circ}$  where B = (L/2)-3 and L is measured in inches. Consult factory for the clearance requirements of models not tabulated above.





ERD mounted to DIN-Rail in the long orientation

KEPCO, INC. • 131-38 Sanford Avenue • Flushing, NY 11352 USA • Tel: (718) 461-7000 • Fax: (718) 767-1102 Email: hq@kepcopower.com • www.kepcopower.com/din.htm